

**TOWN OF MILLVILLE
BOARD OF SELECTMEN**

**Minutes of October 24, 2008
2:30 p.m.**

**Members Present: Vice Chairman Tom Petrowicz, Selectman Charlie Poulin and
Selectman John Laura**

**Others Present: Executive Secretary Helen Coffin; Principal Eileen Tetreault;
Custodian Bob Therrien**

The meeting is called to order at 2:30 pm at the Millville Elementary School.

The purpose of the meeting is to review and discuss the pipes and water filtration system with respect to the water issues at the School, and to provide an opportunity for the Board members to ask questions of the custodian in anticipation of the upcoming meeting with the engineer and water operator.

The parties discuss various aspects of the installation of the media filtration system at the School and receive technical information from the custodian. The members evaluate the various pipes and discuss information provided by the engineer. There is a question as to why a sediment filter wasn't installed between the well and multi media filter to catch the excess sediment and iron before hitting the new filter. The members briefly discuss the status of the water tank and the location of the well. Selectman Poulin will stop by the School again on Monday to confirm the various pipe sizes. Selectman Laura would like to address the different metals used on the pipe fittings as this could be causing rust and corrosion. Brief discuss regarding the purchase of a smaller water tank to be used strictly for potable water. The Board will get back to the custodian after the meeting next week as to the next steps to be taken.

Motion by Poulin, second by Laura, to adjourn. Motion passes by unanimous vote.

Respectfully submitted,
Helen M. Coffin

Thomas Petrowicz, Vice Chairman

Charles Poulin

John Laura

APPROVED AND SIGNED 11/03/08